



**THE ANGUILLA ELECTRICITY COMPANY LIMITED
(ANGLEC)**

**REQUEST FOR QUOTATION
Fire Extinguisher, Fire Alarm System and Fire Protection
System Annual Inspection, Maintenance and Certification**

**Release Date:
October 13, 2020**

**Closing Date:
November 6, 2020**

SPECIFICATIONS AND SCOPE OF WORK

ANGLEC intends to award a two (2) year service contract (with the possibility for renewal) for Fire Extinguisher, Fire Alarm System and Fire Protection System Annual Inspection, Maintenance and Certification. All systems and equipment must be inspected, maintained and certified in accordance with the current National Fire Protection Association (NFPA) standard. The Contractor shall use the manufacturer's recommended recharge agent, lubricants, and replacement parts or materials specially listed for use for all systems and equipment. Maintenance, servicing, inspections, and recharging shall be performed by trained persons, having available the appropriate servicing certificates, manuals and the proper tools.

Equipment

The Anguilla Electricity Company Limited (ANGLEC) has various sizes and types of Fire Extinguishers and Fire Protection and Alarm Systems. The Contractor shall examine the premises and shall satisfy themselves with the general condition of the premises, obstructions and the location, condition, number of systems and extinguishers etc. of any existing contract work and/or mechanical or electrical work prior to delivering their proposal. No allowance will subsequently be made to the contractor, by reason of their own failure to have made such an examination, or on account of any error or oversight on their part. Should any discrepancies, errors, conflict or items needing clarification be discovered in the plans and or the specifications, the Contractor shall notify ANGLEC in writing. The contract shall cover the equipment as noted below:

1. *Transmission and Distribution Department (Main Building – T&D Office, Vehicle Service Centre, Company Vehicles and In Storage)*
 - › Fire Extinguishers

2. *Administration Department (Main Building – Admin Office, Satellite Office, Stores and In Storage)*
 - › Fire Extinguishers

3. *Generation Department (Control Room, Workshop, Engine Hall and Environs)*

- › Fire Extinguishers
- › Fire Pump and Connections
- › Fire Box and Contents
- › Preaction System
- › Fire Hydrants
- › NOVEC System
- › Pull Stations
- › Standpipe System
- › Smoke Detectors
- › Strobes and Horns
- › Fire Alarm Control Panel
- › Foam System
- › Deluge Water Sprinkler System
- › Other
- › Wet Sprinkler System
- › Sprinkler Heads

Annual Inspection and Maintenance – Fire Extinguishers

Contractor shall inspect Fire Extinguishers once annually. Inspection of Fire Extinguishers shall include the following:

1. Location in designated place
2. No obstruction to access or visibility
3. Operating instructions on nameplate legible and facing outward
4. Safety seals and tamper indicators not broken or missing
5. Fullness determined by weighing or “hefting”
6. Examination for obvious physical damage, corrosion, leakage, or clogged nozzle
7. Pressure gauge reading or indicator in the operable range or position

The Contractor shall take immediate corrective action when an inspection of any Fire Extinguisher reveals a deficiency in any of the conditions listed above.

The Contractor shall perform maintenance on Fire Extinguishers at intervals of not more than once a year, providing the appropriate maintenance service in accordance with National Fire Protection Association Standards for Portable Fire Extinguishers, Fire Alarms Systems and Fire Protection Systems. Contractor’s maintenance procedures shall include a thorough examination of the basic elements of a fire extinguisher as determined below:

1. Mechanical parts of all fire extinguishers
2. Extinguishing agent of cartridge- or cylinder-operated dry chemical, stored-pressure, loaded stream, and pump tank fire extinguishers.
3. Expelling means of all fire extinguishers
4. Seals or Tamper Indicators: a new tamper seal shall be installed after maintenance.
5. Provide recommendations for repair or replacement of defective parts, including replacement wall hooks and vehicle brackets.

The Contractor shall provide a tag or label securely attached that indicates the month and year the maintenance was performed and that identifies the person performing the service.

Recharging – Fire Extinguishers

Contractor shall recharge any rechargeable-type Fire Extinguisher after any use or as indicated by an inspection or when performing maintenance. When performing the recharging, the recommendation of the manufacturer shall be followed.

Hydro-static Testing – Fire Extinguishers

At intervals not exceeding 5 years or 12 years (based on the Fire Extinguisher's type), the Contractor shall hydrostatically test all rechargeable fire extinguishers. The hydro-static test shall be conducted within the calendar year of the specified test interval. In no case shall an Extinguisher be recharged if it is beyond its specified test date without ANGLEC being informed about the need for testing. Non-rechargeable fire extinguishers shall not be hydrostatically tested but shall be removed from service at a maximum interval of 5 years or 12 years (based on the Fire Extinguisher's type), without hydro-static testing.

A Hydro-static test shall always include both an internal and external visual examination of the cylinder. Hydro-static testing shall be performed by persons trained in pressure testing procedures and safeguards who have suitable testing equipment, facilities, and appropriate servicing manuals available. Hydro-static testing must be performed by technicians certified to test and evaluated low- and high-pressure systems.

The Contractor shall maintain a permanent record for each cylinder tested and provide a copy to ANGLEC.

Annual Inspection and Maintenance – Complete Fire Protection and Alarm Systems

The Contractor will be required to test all listed systems for proper operation, identify any potential malfunctions within the systems and equipment as well as provide preventative maintenance to specified locations. Preventative maintenance shall include, but not be limited to:

1. All ceiling and duct smoke detectors shall be disassembled and cleaned prior to testing. All detectors shall be tested per manufacture recommendation.
2. Contractor shall test for and indicate whether or not the building alarm is connected to a central monitoring point.
3. Fire Control Panel shall be tested for all functions and signal current and noted in the report.
4. All pull stations will be pulled and tested for proper operation.
5. All water flow switches shall be adjusted.
6. All tamper switches shall be tested for proper operation.

Any repairs required, as a result of testing shall be submitted to ANGLEC for approval prior to any repairs being made. The Contractor must refer to the 'Pricing and Evaluation' as well as the 'Equipment' section.

New Parts and Additions - Complete Fire Protection and Alarm Systems

After the inspection and certification of the complete Fire Protection and Alarm System has been conducted, if needed, the Contractor shall provide ANGLEC with a quotation for new parts or additions to the system.

QUALIFICATIONS

ANGLEC requires that all personnel have and maintain proper certification of all individuals working on any extinguisher or system that ANGLEC requires to be test, recharged, programmed or certified. Proof of certifications of all personnel including subcontractors being properly certified and/or trained must be submitted in response to this request.

The Contractor shall have all the testing equipment available for immediate use.

Once any piece of equipment is taken offsite, its it expected that it / they will be returned to ANGLEC within two (2) weeks.

REPORTING REEQUIPMENTS

The Contractor shall provide service reports and copies of certifications to ANGLEC's designated contact persons. Reports shall include:

- | | | |
|----------------------|-------------------------|---------------------|
| 1. Location | 5. Extinguisher Brand | 9. Repairs Made |
| 2. Serial Numbers | 6. Service Date | 10. Comments |
| 3. Extinguisher size | 7. System Name and Type | 11. Recommendations |
| 4. Extinguisher Type | 8. Work Done | |

The Contractor shall maintain a service and inspection log of all of ANGLEC's equipment serviced during the period of the Contract to be available upon the request of ANGLEC.

PAYMENTS

The Contractor will provide ANGLEC with an invoice for all work performed. Prices for services provided by the Contractor must be quoted in the attached documents as a submitted bid. Cost for repairs have be provided via quotation prior to the repair.

TERM

This Contract shall be for two (2) years only.

INSURANCE

Upon signing, the Contractor acknowledges that all matters of safety and appropriate insurance including, but not limited to Workers' Compensation, General Liability and other forms of insurance will be the sole responsibility of the Contractor. The Contractor must provide a copy of the company insurance to ANGLEC prior to the commencement of the contract.

INDEMNIFICATION (HOLD HARMLESS) CLAUSE

The Contractor agrees to hold harmless and indemnify ANGLEC for all damages, costs and attorney fees that arise out of harm caused to Contractor, Subcontractors and other third parties, known and unknown, by Contractor's performance of the specified work and that the Contractor shall obtain adequate business liability insurance that will cover job and any injuries or illness to Subcontractors or Employees. The Contractor shall be liable for any injury, illness, loss, damage, claim or expense caused by the Contractor or Subcontractors in the execution of this contract.

TERMINATION

ANGLEC shall be entitled to terminate the contract if the Contractor:

1. Fails to comply with the agreed standards and /or scope of works.
2. Abandons the work or otherwise plainly demonstrate the intention not to continue obligated works under the contract.
3. Becomes bankrupt, insolvent or goes into liquidation.
4. Gives or offers to give (directly or indirectly) to any person any bribe, commission, or other thing of value, as an inducement for showing or forbearing to show favor or disfavor to any action in relation to the Contract.
5. Without reasonable excuse fails:

- a. to proceed with the works in accordance with the Scope of Works.
- b. to commence the works within 30 days of the agreed start date.

VARIATIONS

No variation of shall be made to the work stipulated without prior written approval of the Company's authorized representative. Failure to observe this condition may at the sole discretion of the Company result in non-payment for unauthorized works.

WORKING CONDITIONS, HEALTH, HYGIENE, SAFETY AND THE ENVIRONMENT

The Contractor is ultimately responsible for the safety of its personnel and job site. ANGLEC will, however, oversee the operations and provide whatever feedback and instructions that it may deem necessary to ensure, among other things that;

1. The risks of any bodily injury and damage to property during the job performance is low.
2. Public access along the roadway / pathway is maintained as all times.
3. Rules regarding health, hygiene, safety and environment are complied with.
4. General safe work attitude is present.

Where continued breaches regarding safe working conditions is observed, ANGLEC may cease operations immediately at the Contractor's expense (for any situation or activity under its control), which is dangerous or harmful to anyone's health, is unhygienic or poses a safety threat to the environment or public. All consequences arising from the Contractor's non-compliance with any foregoing obligations, including any costs associated with the implementation of the measures taken by ANGLEC in the event of deficiency or negligence on the part of the Contractor, shall be borne solely by the Contractor.

In the event of non-performance by the Contractor of any of the obligations set out in this RFQ, ANGLEC shall have the right to terminate the Contract.

DEFAULT

The occurrence of any of the following shall constitute a material default under this Contract:

1. The failure to make a required payment when due.
2. The insolvency or bankruptcy of either party.
3. Theft or misappropriation of ANGLEC property.
4. Failure to adequately provide services.
5. Act of God.

PRICING AND EVALUATION

Quotes shall be effective from the start of the contract to its end. You may submit the pricing on the attached schedules for the contract cost for the following:

Administration Department

1. Annual Inspection, Maintenance & Certification – Fire Extinguishers
2. Recharge - Fire Extinguishers
3. Hydrostatic Test - Fire Extinguishers

Transmission and Distribution Department

1. Annual Inspection, Maintenance & Certification – Fire Extinguishers
2. Recharge - Fire Extinguishers
3. Hydrostatic Test - Fire Extinguishers

Generation Department

1. Annual Inspection, Maintenance & Certification – Fire Extinguishers
2. Recharge - Fire Extinguishers
3. Hydrostatic Test - Fire Extinguishers
4. Annual Inspection, Maintenance & Certification: Fire Alarm System (Fire Alarm Control Panel, Alarm Initiating Devices, Alarm Notification Devices, Fire Boxes, Other)

5. Annual Inspection, Maintenance & Certification: Fire Protection Systems (Deluge Water / Foam Sprinkler System and Sprinkler Heads, Wet Sprinkler System, Standpipe System, Fire Pump Flow Test, Preaction System, NOVEC Gas System, Fire Hydrants, Other)

OFFER

ANGLEC reserves the right to accept or reject any or all quotes or portions thereof or to waive any minor irregularities. An offer will be made to the Contractor/s which meets the required specifications and may not be solely based on cost.

ANGLEC reserves to the right to offer portions of the work to one or more Contractors, i.e. for example, one Contractor may be given two (2) Departments, and another may be contracted for services in one (1) Department only. ANGLEC will consider multiple providers for this contract.

ANGLEC also reserves the right to reject all quotes and re-issue a new Request for Quotation (RFQ).

Upon the award of the Contract, further guidelines will be provided regarding the specifics of the Fire Alarm and Protection Systems.

RETURN OF QUOTATIONS

Sealed responses to this request must be submitted on or before November 6, 2020 at 4pm to:

Mrs. Shenique Clare- Mussington

Transmission and Distribution Department

Anguilla Electricity Company Ltd.

Corito

Anguilla

Responses beyond this date and time will not be considered.

ATTACHMENT A

PRICING SCHEDULE - ADMINISTRATION DEPARTMENT

Item	Description	Unit Price	Qty.	Total Price
1	Annual Inspection & Maintenance: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x 6	\$
2	Annual Inspection & Maintenance: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x 9	\$
3	Annual Inspection & Maintenance: 7 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
4	Annual Inspection & Maintenance: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x 2	\$
5	Annual Inspection & Maintenance: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 5	\$
6	Annual Inspection & Maintenance: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
7	Annual Inspection & Maintenance: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Annual Inspection & Maintenance: 2 ½ lb. CO2 Fire Extinguisher	\$	x	\$
9	Annual Inspection & Maintenance: 3 lb. CO2 fire extinguisher	\$	x	\$
10	Annual Inspection & Maintenance: 5 lb. CO2 Fire Extinguisher	\$	x 11	\$
11	Annual Inspection & Maintenance: 10 lb. CO2 Fire Extinguisher	\$	x	\$
12	Annual Inspection & Maintenance: 15 lb. CO2 Fire Extinguisher	\$	x	\$
13	Annual Inspection & Maintenance: 20 lb. CO2 Fire Extinguisher	\$	x	\$
14	Annual Inspection & Maintenance: 50 lb. CO2 Fire Extinguisher	\$	x	\$
15	Annual Inspection & Maintenance: 100 lb. CO2 Wheeled Fire Extinguisher	\$	x	\$
16	Annual Inspection & Maintenance: 5lb Purple K Fire Extinguisher	\$	x	\$
TOTAL:				\$ _____

ATTACHMENT B
PRICING SCHEDULE - TRANSMISSION AND DISTRIBUTION DEPARTMENT

Item	Description	Unit Price	Qty.	Total Price
1	Annual Inspection & Maintenance: 2 ½ lb. ABC Dry Chemical Fire Extinguisher	\$	x 2	\$
2	Annual Inspection & Maintenance: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
3	Annual Inspection & Maintenance: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x 15	\$
4	Annual Inspection & Maintenance: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x 23	\$
5	Annual Inspection & Maintenance: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
6	Annual Inspection & Maintenance: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
7	Annual Inspection & Maintenance: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Annual Inspection & Maintenance: 2 ½ lb. Halon Fire Extinguisher	\$	x 1	\$
9	Annual Inspection & Maintenance: 3 lb. CO2 Fire extinguisher	\$	x	\$
10	Annual Inspection & Maintenance: 5 lb. CO2 Fire Extinguisher	\$	x 1	\$
11	Annual Inspection & Maintenance: 10 lb. CO2 Fire Extinguisher	\$	x 1	\$
12	Annual Inspection & Maintenance: 15 lb. CO2 Fire Extinguisher	\$	x 2	\$
13	Annual Inspection & Maintenance: 20 lb. CO2 Fire Extinguisher	\$	x 2	\$
14	Annual Inspection & Maintenance: 50 lb. CO2 Fire Extinguisher	\$	x	\$
15	Annual Inspection & Maintenance: 100 lb. CO2 Wheeled Fire Extinguisher	\$	x 3	\$
16	Annual Inspection & Maintenance: 5lb Purple K Fire Extinguisher	\$	x	\$
TOTAL:				\$

ATTACHMENT C
PRICING SCHEDULE - GENERATION DEPARTMENT

Item	Description	Unit Price	Qty.	Total Price
1	Annual Inspection & Maintenance: 2 ½ lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
2	Annual Inspection & Maintenance: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
3	Annual Inspection & Maintenance: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
4	Annual Inspection & Maintenance: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
5	Annual Inspection & Maintenance: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
6	Annual Inspection & Maintenance: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
7	Annual Inspection & Maintenance: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Annual Inspection & Maintenance: 2 ½ lb. CO2 Fire Extinguisher	\$	x	\$
9	Annual Inspection & Maintenance: 3 lb. CO2 fire extinguisher	\$	x	\$
10	Annual Inspection & Maintenance: 5 lb. CO2 Fire Extinguisher	\$	x	\$
11	Annual Inspection & Maintenance: 11 lb. CO2 Fire Extinguisher	\$	x 2	\$
12	Annual Inspection & Maintenance: 15 lb. CO2 Fire Extinguisher	\$	x 6	\$
13	Annual Inspection & Maintenance: 20 lb. CO2 Fire Extinguisher	\$	x 32	\$
14	Annual Inspection & Maintenance: 50 lb. CO2 Fire Extinguisher	\$	x	\$
15	Annual Inspection & Maintenance: 100 lb. CO2 Wheeled Fire Extinguisher	\$	x 6	\$
16	Annual Inspection & Maintenance: 5lb Purple K Fire Extinguisher	\$	x 2	\$
17	Annual Inspection & Maintenance: Fire Alarm System (Fire Alarm Control Panel, Alarm Initiating Devices, Alarm Notification Devices & Fire Boxes)			\$
18	Annual Inspection & Maintenance: Fire Protection Systems (Deluge Water / Foam Sprinkler System and Sprinkler Heads, Wet Sprinkler System, Fire Pump, Standpipe System, Fire Pump Flow Test, Preaction System, NOVEC Gas System, Fire Hydrants)			\$
TOTAL:				\$

ATTACHMENT D

PRICING SCHEDULE - ADMINISTRATION DEPARTMENT

Item	Description	Unit Price	Qty.	Total Price
1	Recharge: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x 6	\$
2	Recharge: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x 9	\$
3	Recharge: 7 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
4	Recharge: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x 2	\$
5	Recharge: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 5	\$
6	Recharge: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
7	Recharge: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Recharge: 2.5 lb. CO2 Fire Extinguisher	\$	x	\$
9	Recharge: 3 lb. CO2 Fire Extinguisher	\$	x	\$
10	Recharge: 5 lb. CO2 Fire Extinguisher	\$	x 11	\$
11	Recharge: 10 lb. CO2 Fire Extinguisher	\$	x	\$
12	Recharge: 15 lb. CO2 Fire Extinguisher	\$	x	\$
13	Recharge: 20 lb. CO2 Fire Extinguisher	\$	x	\$
14	Recharge: 50 lb. CO2 Fire Extinguisher	\$	x	\$
15	Recharge: 100 lb. CO2 Wheeled Fire Extinguisher	\$	x	\$
16	Recharge: 5lb Purple K Fire Extinguisher	\$	x	\$
TOTAL:				\$ _____

ATTACHMENT E
PRICING SCHEDULE - TRANSMISSION AND DISTRIBUTION DEPARTMENT

Item	Description	Unit Price	Qty.	Total Price
1	Recharge: 2 ½ lb. ABC Dry Chemical Fire Extinguisher	\$	x 2	\$
2	Recharge: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
3	Recharge: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x 15	\$
4	Recharge: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x 23	\$
5	Recharge: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
6	Recharge: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
7	Recharge: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Recharge: 2.5 lb. Halon Fire Extinguisher	\$	x 1	\$
9	Recharge: 3 lb. CO ₂ Fire Extinguisher	\$	x	\$
10	Recharge: 5 lb. CO ₂ Fire Extinguisher	\$	x 1	\$
11	Recharge: 10 lb. CO ₂ Fire Extinguisher	\$	x 1	\$
12	Recharge: 15 lb. CO ₂ Fire Extinguisher	\$	x 2	\$
13	Recharge: 20 lb. CO ₂ Fire Extinguisher	\$	x 2	\$
14	Recharge: 50 lb. CO ₂ Fire Extinguisher	\$	x	\$
15	Recharge: 100 lb. CO ₂ Wheeled Fire Extinguisher	\$	x 3	\$
16	Recharge: 5lb Purple K Fire Extinguisher	\$	x	\$
TOTAL:				\$

**ATTACHMENT F
PRICING SCHEDULE - GENERATION DEPARTMENT**

Item	Description	Unit Price	Qty.	Total Price
1	Recharge: 2 ½ lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
2	Recharge: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
3	Recharge: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
4	Recharge: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
5	Recharge: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
6	Recharge: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
7	Recharge: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Recharge: 2.5 lb. CO ₂ Fire Extinguisher	\$	x	\$
9	Recharge: 3 lb. CO ₂ Fire Extinguisher	\$	x	\$
10	Recharge: 5 lb. CO ₂ Fire Extinguisher	\$	x	\$
11	Recharge: 10 lb. CO ₂ Fire Extinguisher	\$	x 2	\$
12	Recharge: 15 lb. CO ₂ Fire Extinguisher	\$	x 6	\$
13	Recharge: 20 lb. CO ₂ Fire Extinguisher	\$	x 32	\$
14	Recharge: 50 lb. CO ₂ Fire Extinguisher	\$	x	\$
15	Recharge: 100 lb. CO ₂ Wheeled Fire Extinguisher	\$	x 6	\$
16	Recharge: 5lb Purple K Fire Extinguisher	\$	x 2	\$

TOTAL: \$ _____

ATTACHMENT G

PRICING SCHEDULE - ADMINISTRATION DEPARTMENT

Item	Description	Unit Price	Qty.	Total Price
1	Hydro-static Test: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x 6	\$
2	Hydro-static Test: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x 9	\$
3	Hydro-static Test: 7 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
4	Hydro-static Test: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x 2	\$
5	Hydro-static Test: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 5	\$
6	Hydro-static Test: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
7	Hydro-static Test: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Hydro-static Test: 2 ½ lb. CO2 Fire Extinguisher	\$	x	\$
9	Hydro-static Test: 3 lb. CO2 Fire Extinguisher	\$	x	\$
10	Hydro-static Test: 5 lb. CO2 Fire Extinguisher	\$	x 11	\$
11	Hydro-static Test: 10 lb. CO2 Fire Extinguisher	\$	x	\$
12	Hydro-static Test: 15 lb. CO2 Fire Extinguisher	\$	x	\$
13	Hydro-static Test: 20 lb. CO2 Fire Extinguisher	\$	x	\$
14	Hydro-static Test: 50 lb.CO2 Fire Extinguisher	\$	x	\$
15	Hydro-static Test: 100 lb. CO2 Wheeled Fire Extinguisher	\$	x	\$
16	Hydro-static Test: 5lb Purple K Fire Extinguisher	\$	x	\$
TOTAL:				\$ _____

ATTACHMENT H
PRICING SCHEDULE - TRANSMISSION AND DISTRIBUTION DEPARTMENT

Item	Description	Unit Price	Qty.	Total Price
1	Hydro-static Test: 2 ½ lb. ABC Dry Chemical Fire Extinguisher	\$	x 2	\$
2	Hydro-static Test: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
3	Hydro-static Test: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x 15	\$
4	Hydro-static Test: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x 23	\$
5	Hydro-static Test: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
6	Hydro-static Test: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
7	Hydro-static Test: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Hydro-static Test: 2 ½ lb. Halon Fire Extinguisher	\$	x 1	\$
9	Hydro-static Test: 3 lb. CO2 Fire Extinguisher	\$	x	\$
10	Hydro-static Test: 5 lb. CO2 Fire Extinguisher	\$	x 1	\$
11	Hydro-static Test: 10 lb. CO2 Fire Extinguisher	\$	x 1	\$
12	Hydro-static Test: 15 lb. CO2 Fire Extinguisher	\$	x 2	\$
13	Hydro-static Test: 20 lb. CO2 Fire Extinguisher	\$	x 2	\$
14	Hydro-static Test: 50 lb.CO2 Fire Extinguisher	\$	x	\$
15	Hydro-static Test: 100 lb. CO2 Wheeled Fire Extinguisher	\$	x 3	\$
16	Hydro-static Test: 5lb Purple K Fire Extinguisher	\$	x	\$
TOTAL:				\$

ATTACHMENT I
PRICING SCHEDULE - GENERATION DEPARTMENT

Item	Description	Unit Price	Qty.	Total Price
1	Hydro-static Test: 2 ½ lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
2	Hydro-static Test: 3 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
3	Hydro-static Test: 5 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
4	Hydro-static Test: 10 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
5	Hydro-static Test: 15 lb. ABC Dry Chemical Fire Extinguisher	\$	x 1	\$
6	Hydro-static Test: 20 lb. ABC Dry Chemical Fire Extinguisher	\$	x 4	\$
7	Hydro-static Test: 50 lb. ABC Dry Chemical Fire Extinguisher	\$	x	\$
8	Hydro-static Test: 2 ½ lb. CO2 Fire Extinguisher	\$	x	\$
9	Hydro-static Test: 3 lb. CO2 Fire Extinguisher	\$	x	\$
10	Hydro-static Test: 5 lb. CO2 Fire Extinguisher	\$	x	\$
11	Hydro-static Test: 11 lb. CO2 Fire Extinguisher	\$	x 2	\$
12	Hydro-static Test: 15 lb. CO2 Fire Extinguisher	\$	x 6	\$
13	Hydro-static Test: 20 lb. CO2 Fire Extinguisher	\$	x 32	\$
14	Hydro-static Test: 50 lb.CO2 Fire Extinguisher	\$	x	\$
15	Hydro-static Test: 100 lb. CO2 Wheeled Fire Extinguisher	\$	x 6	\$
16	Hydro-static Test: 5lb Purple K Fire Extinguisher	\$	x 2	\$

TOTAL: \$ _____

ATTACHMENT J
ADDITIONAL INFORMATION

FULL COMPANY EQUIPMENT LIST

1	ESTIMATED TIME NEEDED FOR REPAIRS
2	
3	
4	ESTIMATED TIME NEEDED FOR HYDRO-STATIC TEST
5	
6	
7	ESTIMATED TIME NEEDED TO PROVIDE NEW EXTINGUISHER
8	
9	
10	

**ESTIMATED TIME NEEDED FOR ANNUAL
INSPECTION (ALL DEPARTMENTS)**

Administration Department _____

Transmission and Distribution Department _____

Generation Department _____

**ATTACHMENT K
RESPONDING COVER LETTER**

To: The Anguilla Electricity Company Limited

Subject: **REQUEST FOR QUOTATION - Fire Extinguisher, Fire Alarm System and Fire Protection System Inspection and Maintenance**

The enclosed is submitted in response to the above-referenced Request for Quotation. We have carefully read and examined the Request for Quotation and have conducted such other investigations as were prudent and reasonable in preparing the Response.

COMPANY DETAILS

Company Name:

Contact Person (s):

Address:

Certifications:

e-mail address:

Date:
